

Great Prairie Oasis L.L.C.
dba Sunland Water Company
7502 E. Hazelwood Street
Scottsdale, Arizona 85251



0000150477

Arizona Corporation Commission
Docket Control Center
1200 West Washington Street
Phoenix, AZ 85007

ORIGINAL

December 17th, 2013

Dear Sir or Madam,

Please find enclosed an original and thirteen copies of the Arizona Department of Environmental Quality Approval of Construction per decision #74091 for and relating to:

Great Prairie Oasis L.L.C


DBA Sunland Water Company

Docket numbers: W-04015A-12-0051 and W-04015A-12-0050


Arizona Corporation Commission

DOCKETED

DEC 17 2013

DOCKETED BY	
-------------	---

Sincerely,



Beth Wand

Sunland Water Company

RECEIVED
2013 DEC 17 A 8:47
CORP COMMISSION
DOCKET CONTROL



Janice K. Brewer
Governor

ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY

1110 West Washington Street • Phoenix, Arizona 85007
(602) 771-2300 • azdeq.gov



Henry R. Darwin
Director

APPROVAL OF CONSTRUCTION

Project Description:

Sunland Water Company. AOC Permit for 1-40 hp, 350 gpm New Source Production Well No. 2 (55-606220) and Blended with Existing Well No. 1 (55-606215) and approximately 2,800 LF of 6-inch Class 150 PVC Waterlines and Related Fittings. Water System to perform Weekly Field Testing of Finished Water as an indicator that Arsenic and Nitrate levels are below Drinking Water MCLs.

Location:

Casa Grande, AZ

Project Owner:

Sunland Water Company, c/o Ms. Beth Wand

Address:

7502 E. Hazelwood Street, Scottsdale, AZ 85251

The Arizona Department of Environmental Quality (ADEQ) hereby issues an Approval of Construction for the above-described facility based on the following provisions of Arizona Administrative Code (A.A.C.) R18-5-507 et seq.

On October 4, 2011, ADEQ issued a Certificate of Approval to Construct for the referenced project.

On November 23, 2013 William E. Collings, P.E., certified the following:

- A final construction inspection was conducted on November 14, 2013;
- The referenced project was constructed according to the as-built plans and specifications and ADEQ's Certificate of Approval to Construct;
- Water system pressure and leakage tests were conducted on October 31, 2013, and the results were within the allowable leakage rates;
- ADEQ reserves the right to revoke AOC Permit if Initial Start-Up Monitoring Plan is not completed, per AAC R18-4-105, Subpart C-Monitoring and Analytical Requirements §141.23(c)(9);
- The Well and Components were disinfected according to an ADEQ-approved method; and
- The applicant has the right to appeal this AOC Permit. Appeal information is on reverse side of this Permit.

Microbiological samples were collected on November 7, 2013 and analyzed on November 8, 2013 by Arizona City Sanitary District, ADHS License No. AZ0488. The sample results were negative for total coliform.

This Approval of Construction authorizes the owner to begin operating the above-described facilities as represented in the approved plan on file with the ADEQ. Be advised that A.A.C. R18-5-124 requires the owner of a public water system to maintain and operate all water production, treatment and distribution facilities in accordance with ADEQ Safe Drinking Water Rules.

FMS

PWS No.: 11-334

LTF No.: 59172

c: TEU File No.: 20110140


CRO Approval of Construction File

Pinal County Health Department

Pinal County Planning & Zoning Department

AZ Corporation Commission

Engineer


John Calkins, Manager
Drinking Water Section


Date Approved

Southern Regional Office
400 West Congress Street • Suite 433 • Tucson, AZ 85701
(520) 628-6733

RIGHT TO APPEAL INFORMATION

The Arizona Department of Environmental Quality's review of this application was subject to the requirements of the licensing time frames ("LTF") statute under Arizona Revised Statutes ("A.R.S.") § 41-1072 through § 41-1079 and the LTF rules under Arizona Administrative Code ("A.A.C.") R18-1-501 through R18-1-525. This Notice is being issued within the overall time frame for your application.

ADEQ hereby approves your application for Approval of Construction Drinking Water Facilities under A.R.S. § 49-351. Your copy of the Approval of Construction Permit is on the reverse side of this Right to Appeal Information sheet.

This decision is an appealable agency action under A.R.S. § 41-1092. You have a right to request a hearing and file an appeal under A.R.S. § 41-1092.03(B). You must file a written Request for Hearing or Notice of Appeal within **30 days** of your receipt of this Notice. A Request for Hearing or Notice of Appeal is filed when it is received by ADEQ's Hearing Administrator as follows:

Office of Administrative Counsel
Arizona Department of Environmental Quality
1110 W. Washington Street
Phoenix, AZ 85007

The Request for Hearing or Notice of Appeal shall identify the party, the party's address, the agency and the action being appealed and shall contain a concise statement of the reasons for the appeal. Upon proper filing of a Request for Hearing or Notice of Appeal, ADEQ will serve a Notice of Hearing on all parties to the appeal. If you file a timely Request for Hearing or Notice of Appeal you have a right to request an informal settlement conference with ADEQ under A.R.S. § 41-1092.06. This request must be made in writing no later than **20 days** before a scheduled hearing and must be filed with the Hearing Administrator at the above address.

Please contact Frank M. Smaila at (602) 771-4237 or fms@azdeq.gov if you have questions regarding this Notice or the Certificate of Approved of Construction.